

**Fire Department Water Tanker Shuttle Accreditation**

Presented To: Tyendinaga Township

**ACCREDITED FIRE STATIONS**

F.S #1 Melrose (6)

---

---

---

Date Test Passed: October 9<sup>th</sup> 2019

Flow Achieved: 626 I.G.P.M. 2,850 LITERS/MIN.

Two (2) Hour Test Time



Signed: *Elaine Rose*  
Elaine Rose  
Partner

**This Certificate Expires on: October 1<sup>st</sup> 2024**